


STANDARD DEVICE OPTIONAL ANALOG DEVICE

1 CLEAR PVC STANDPIPE: FOR LEVEL VIEWING



HDPE MOUNTING BOARD ON ALUMINUM FRAME




DWYER MINIHELIC GAUGE No. 2-5010 (0 - 60" WC): AERATOR PRESSURE MONITORING



DWYER MINIHELIC GAUGE No. 2-5060 (0 - 10" WC):
AIR FILTER PRESSURE MONITORING





HIGH WATER LEVEL SWITCH (TETHER NC): SJE Signalmaster No. 1006046 SHUTS DOWN WELL SUPPLY



DWYER 616W-6-LCD PRESSURE TRANSDUCER (4-20 mA, 0 - 60" WC):
MONITORS AERATOR PRESSURE AND AUTO

ALARM IF AERATORS FOUL AND REQUIRE MAINTENANCE



DWYER 616W-3-LCD PRESSURE TRANSDUCER
(4-20 mA, 0 - 10" WC):
MONITORS AIR FILTER DIFFERENTIAL PRESSURE



MONITORS AIR FILTER DIFFERENTIAL PRESSURE
AND AUTO ALARM IF FILTER ELEMENT IS DIRTY AND REQUIRES MAINTENANCE






(4-20 mA pressure probe):
SIGNAL TO PUMP VFD TO CONTROL LEVEL IN STRIPPER +/- 1". ALSO CAN
GIVE SET POINTS FOR HIGH AND LOW WATER LEVEL



HDPE MOUNTING BOARD ON ALUMINUM FRAME





INSTALLED IN STANDPIPE

AIR STRIPPER MONITORING & PROTECTION
GRAVITY OR PUMPED SYSTEMS
LOWRY SYSTEMS
146 SOUTH STREET, BLUE HILL, ME 04614 ME
SIZE
D SHEET 1 of 1

DATE: DEC 28, 2017